

## Product Evaluation

RV134 | 0326

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** RV-134**Effective Date:** March 1, 2026**Re-evaluation Date:** March 2030**Product Name:** Python™ Pro 4 ft STD Ridge Vents

**Manufacturer:** Marco Industries Inc.  
4150 S 100th E Ave, Suite 301  
Tulsa, OK 74146-3650  
(800) 800-8590

**General Description:**

| Product Name                    | Description       | Design Pressure Rating |
|---------------------------------|-------------------|------------------------|
| Python™ Pro 4 ft Ridge STD Vent | 4' Ridge STD Vent | -90.23 psf             |

**Limitations:**

**Roof Deck:** The roof deck must consist of minimum 7/16" thick wood structural panels (plywood or OSB). In addition, the roof deck must satisfy the adopted building code requirements. Roof framing must not exceed 24" on center.

**Roof Slope:** Install the ridge vents on roofs with a minimum slope of 2:12, up to a maximum slope of 12:12.

**Installation:**

**General:** Cover the ridge vents with asphalt roof shingles that comply with the requirements of the IRC and IBC. Installation of the ridge vents must comply with the instructions set forth in the manufacturer's instructions and this product evaluation report.

**Attachment of Roof Vents to Roof Deck:**

Secure the roof vents to the roof deck with 3" long, galvanized, ring shank roofing nails with a minimum 3/8" inch diameter head. Locate the fasteners approximately 1" from each end and 6" on center. The fasteners must be long enough to penetrate completely through the roof deck.

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and IBC.